

LASER DISTANCE METER

INSTRUCTION MANUAL



NF-270

ORIGINAL AUTHENTIC











Please read the complete instructions including safety precautions before attempting any testing.

Please read all of the operational guide and safety regulations in this manual before operation. Improper operations without complying with this manual guided could cause damage to the device, influence on measurement result or bodily injury to the user.

↑ The instrument is not allowed to disassemble or repair on any ways. It is forbidden to do any illegal modification or performance change for laser emitter. Please keep it out of reach of children and avoid using by any irrelevant personnel.

↑ It is strictly prohibited to shoot eyes or other parts. of body with the laser; it is not allowed to take the laser to shoot any objects' surface with strong reflecting.

↑ Due to electromagnetic radiation interference to other equipment and devices, please don't use the meter in the plane or around medical equipment, don't use it in inflammable, explosive environment.

Discarded batteries or meter device shall not process just like household garbage, please handle them in line with related law and regulations.

Any quality issues or any questions on the meter, please contact local distributors or manufacturer in time, we are ready to offer solutions for you.


Table of Contents

C	Overview	0
1	.Display instruction	0
2	Product features	0
3	Operation instruction	0
3	3.1.Turn on&off	C
3	3.2.Single measurement	0
3	3.3.Continuous measurement	0
3	3.4.Area&circumference measurement	0
3	3.5.Volume measurement	0
3	3.6.Area continuous measurement	0
3	3.7.Pythagorean measurement	C
S	Secondary Pythagorean measurement ①	0
S	Secondary Pythagorean measurement ②	0
3	3.8.Countdown measurement	0
3	3.9.Addition&subtraction measurement	0
3	3.10.Unit switching	0
3	3.11.Benchmark switching	0
3	3.12.Record query	0
3	3.13.Setting	0
4	I.Technical parameters	0
	i.Packing list	
	Frror reason and solution	

Overview


NF-270 is used to measure distance, length, height, width, and area, volume.

It is also with the function of Pythagorean measurement, voice indicator, record query, and bidirectional blisters ect.



NF-270


1.Display instruction



1	Battery condition	7	Setting	
2	Веер	8	Display	
3	Buzzer	9	Data storage	
4	Laser function opener	10	Data storage number	
5	Benchmark point	11	Signal	
6	Area/volume/	12	Auxiliary indicator	
	Pythagorean indicator	13	Unit	

01

2.Product features



3. Operation instructions

3.1. Turn on & off

Long press " 2s to turn on, Long press " 2s to turn off.

3.2. Single measurement

Press " turn on the laser and Press " again, the result will display on the screen.

3.3. Continuous measurement

Long press " [2s to go in, the MAX &MIN will shows, press " [2s to go in, the MAX &MIN will shows, press " [2s to go in, the MAX &MIN will stop if no operation after 3 mins.

3.4 Area&circumference measurement

Under area & circumference measurement, press " [rea] " to measure the length and width of the area, the result will display the circumference on the third line and the area data display on the last line.

3.5 Volume measurement

Under volume measurement, press " [166]" to measure the length, width, height, the result will display on the screen.

3.6 Area continuous measurement

Under Area continuous measurement,press
" [MEAS] " to measure the height of the wall,press

" MAS "to measure the width ① of the wall ①, the result will display the area of wall ①;

the result will display the area of wall \bigcirc ;

Press "Meas" to measure the width @ of the wall @, the result will display the area of Wall @, and so on,the sum of the area is the height x (width @+width@+width @+width @+width @




3.7 Pythagorean measurement

Under Area continuous measurement, press
" it o enter first Pythagorean measurement, press " it o get ①&② values, it will work out the height "L" on the screen.



Secondary Pythagorean measurement 1

Under the first Pythagorean measurement, press " 👪 " to enter the second Pythagorean measurement. Press " 🕮 " to get 🛈, 2&3" values, it will work out the height "L" on the screen.



${\bf Secondary\, Pythagorean\, measurement @}$

Under the second Pythagorean measurement \bigcirc , Press " \bowtie " to get \bigcirc , \bigcirc 2&3 values, it will work out the height "L" on the screen.



3.8 Countdown measurement

Under the second Pythagorean measurement ②, press " ② " to enter count down measurement. When countdown time is up,it will work out the height "L" on the screen.



3.9 Addition&subtraction measurement

3.10 Unit switching


3.11 Benchmark switching



3.12 Record query

3.13 Setting

Press " # and " " 3s to go in, the flashing arrow on the screen indicates that the Buzzer switch setting has been entered. By press " # and " " o go self-help calibration setting, by press " # and " " o go self-help calibration setting, by press " # and " " o go self-help calibration setting, by press " # and " " o to quist the parameters, press " 0 o to quit.



4. Technical parameters

Model number	NF-270			
Measuring range	As indicated on the label			
Accuracy	±1.5mm(d*0.005%)			
LCD screen	2.0 inch HD screen			
Wavelength &Output	620-670nm,<1mW			
Laser level	Class II			
Lateral bubble	√			
Vertical bubble	√			
Laser-off	No operation for 30 s			
Auto-off	No operation for 180 s			
Single measuring	√			
Continuity measuring	√			
Max/Min	√			
Area measuring	√			
Circumference measuring	√			
Wall area measuring	√			
Volume measuring	√			
Pythagorean measuring	√			
Countdown	√			
Addition&subtraction measuring	√			
Unit switch	M/ft/in/ft+in			
Benchmark switch	Front/end benchmark			

Веер	√
Data storage	99 set
Working temperature	0°C~40°C
Storage temperature	-20°C~60°C
Battery type	1.5V AAA*3pcs
Dimension	120*52*29mm

5.Packing List

1	Device	1pc
2	Giftbox	1pc
3	User manual	1pc
4	Certification	1pc
5	Lanyard	1pc

09

6.Error reasons and solution

Code	Reason	Solution				
203	High or low temperature	Measure at the required temperature range				
220	Low battery	Replace new battery				
254	Wrong calculate	Measure again in correct operation				
255	Weak signal	Test strong reflection ablility of target				
256	Strong signal	Don't measure under strong light				
257	Out of measure range	Measure within the range				
300	Harware error	Restart, or contact dealer if it happens again				

	N	OYAI	FA	精	羽鼠 [°]	深	圳市	诺	方疗	引电·	子有限公司
编号	201	202	301	302	303	304	305	比例:	1:1		304-H2901-0001
类目	塑胶件	五金类	镜片	PVC贴纸	不干胶贴	说明书	包装盒	单位:	mm	品号:	
选择						√		设计	CZG	88	NF-270说明书骑马订英文-V1 20240314
306	307	308	309	310	311	312	313	核准		m-n:	
彩卡	吸塑	工具包	PE袋	纸箱	宣传单	合格证	打印标签	标准:	- √	文件类型	做货文件(相较于打样文件,调整了参数表信息)
								定制		XITXX:	
制作日期		日期 2024.03.14		样式	骑马订	订 印刷材质		材质	128g双铜纸		
印刷要求		要求 彩色		页码	16P	m m 20 =		27 =			
尺寸大小		大小 100×55mm		版本	V1		变更记录				